

Martec Pty Ltd 6 Austool PI | Ingleburn, NSW 2565 P: 02 8778 7500 F: 02 8778 7555 E: customerservice@martecltd.com.au




PLEASE READ THESE INSTRUCTIONS CAREFULLY BEFORE INSTALLATION.
PLEASE RETAIN INSTRUCTIONS FOR FUTURE REFERENCE.

Tradetec Prime Downlight







### **PRODUCT FEATURES**

- 3 year replacement warranty
- Die cast aluminium frame
- Dimmable to 10%
- Polycarbonate lens
- Input power 13W
- 35,000 hour average lamp life

### **INSTALLATION**

- This unit MUST be installed and wired by a qualified electrical contractor
- For maximum number per circuit breaker, use the recommended quantities as for a standard mains 50w lamp (or 100w R80)
- Ensure that the area that the unit is to be fitted has a minimum height clearance of 50mm
- Cut a suitable hole in the ceiling for each unit ensuring no positions are under joists, cables, pipes etc.
- Disconnect mains supply prior to wiring

PRODUCT	HOLE SIZE
TLPDXXX	77mm - 92mm

- Terminate cables at primary side of driver ensuring cable clamp is in place
- Feed springs through ceiling hole slowly releasing unit up to the ceiling and the springs will hold fitting in place
- Fixture control gear/driver MUST BE MOUNTED ABOVE any insulation covering the luminaire
- For indoor use Ta = 25°C

## FOR AUSTRALIAN USE ONLY

RISK OF FIRE - Required clearance from structural members

and building elements

## FOR NEW ZEALAND USE ONLY

RISK OF FIRE - Required clearance from structural members

and building elements

SCB = 0mm HCB = 50mm

MIC = 25mm

### **INSULATION**

#### 13W

- Thermal insulation clearance class-IC covered; meaning that the
   Prime LED down light can be covered entirely by insulation
- Building insulation abutting or is within 100mm horizontally of the luminaire must meet the following requirements: Be of a type that can maintain its dimensions and structural integrity when exposed to a maximum surface temperature of the class of the luminaire, being 90°C; Be of a type that can withstand a 30 second needle flame test carried out in accordance with AS/NZS 60695.11.5 with a flame applied to all surfaces of the sample
- Insulation types which should be used with this fitting are glass wool (Pink Batts) & polyester

# **IMPORTANT NOTE:**

THIS FIXTURE MUST NOT BE INSTALLED WITH LOOSE FILL INSULATION (AS DEFINED IN NZS 4246) SUCH AS MACERATED PAPER AND WOOL.

FIXTURE CONTROL GEAR/DRIVER MUST BE MOUNTED ABOVE ANY INSULATION COVERING THE FIXTURE.

### **DIMMING**

The Prime down light can be dimmed to 10%.

Martec LED down lights are compatible and supported with the Martec MTD300VA dimmer.

All other dimmers may work, but are not supported by Martec.

### **COMPLIANCE**

The Prime range has been tested to comply with relevant Australian/ New Zealand 3001:2007 standards.

- ELECTRICAL SAFETY: Test Report 5986 Spectrum Laboratories
- AS/NZS 6058.2.2:2001 including Amdt A "Recessed Luminaires"
- EMC EN 55015:2006
- CISPR15:2006 Supplier Code No N120
- GMA-103451-EA-005

SCB: Side clearance to building elements; HCB: Height clearance to building elements; SCI: Side clearance to building insulation (non-IC only); MIC: Minimum clearance above building insulation for ventilation